

AC CONDENSING UNIT SCHEDULE

ITEM	MFGR.	MODEL	COOLING 95°F OA			SEER	ELECTRICAL			
			NOMINAL TONS	SENS	TOT		V/ø/Hz	LRA	MCA	MOCp
AC1	RUUD	UANL-060JEZ 5	5	42.9	61	13	208-1-60	134	35	45
AC2	RUUD	UANL-060JEZ 5	5	42.9	61	13	208-1-60	134	35	45
AC3	RUUD	UANL-036JEZ 3	3	27.45	38.5	13	208-1-60	112	24	30

FURNACE SCHEDULE

ITEM	MFGR.	MODEL	CFM	OA* CFM	FILTER TYPE	ESP (IN WC)	FURNACE		DX COOLING COIL				FAN HP	WGT lbs	OVERALL ELECTRICAL DATA		
							MBH	AFUE	T. MBH	SENS MBH	MODEL	NOM. TONS			V/ø/Hz	AMPS	MOCp
F1	RUUD	UGTA-10EZAJS	1975	500	2 IN	.26	105	92	61	42	RCFL-HM6024AC	5	.75	152	115-1-60	9.6	15
F2	RUUD	UGTA-10EZAJS	1950	500	2 IN	.25	105	92	61	42	RCFL-HM6024AC	5	.75	152	115-1-60	9.6	15
F3	RUUD	UGTA-07EYBGS	1200	300	2 IN	.28	75	92.3	37.8	27.05	RCFL-HM3621AC	3	.75	123	115-1-60	9.6	15

FAN SCHEDULE

ITEM	BASIS OF DESIGN	MODEL	CFM	ELECTRICAL			E.S.P. IN. W.C.	REMARKS
				V/ø/Hz	WATTS	FLA		
F1	GREENHECK	SP-B150	150	115/1/60	129	1.1	.25	WALL VENT, BACK DRAFT DAMPERS, BIRD SCREEN
F2	GREENHECK	SP-B150	150	115/1/60	129	1.1	.25	WALL VENT, BACK DRAFT DAMPERS, BIRD SCREEN
F3	GREENHECK	SP-B150	150	115/1/60	129	1.1	.25	WALL VENT, BACK DRAFT DAMPERS, BIRD SCREEN
F4	GREENHECK	SP-B150	150	115/1/60	129	1.1	.25	WALL VENT, BACK DRAFT DAMPERS, BIRD SCREEN





KEYED NOTES

- 1 PROVIDE PLENUM RETURN WITH 1/2" HARDWARE CLOTH AT THE END OF THE DUCTWORK ABOVE CEILING.
- 2 PROVIDE CONDENSATE DRAIN TO BUILDING EXTERIOR WITH TRAP.
- 3 PROVIDE OUTSIDE AIR INTAKE THROUGH ROOF FLASHED WITH INSECT SCREEN AND RAIN CAP.

GENERAL NOTES

- 1 DUCT SIZES NOTED ARE CLEAR.
- 2 PROVIDE PVC COMBUSTION AND FLUE VENTING TO BLDG MFGR PER CODE.
- 3 PROVIDE SECONDARY CONDENSATE PANS UNDER EACH COOLING COIL.

SYMBOLS

-  SUPPLY DIFFUSER
-  RETURN, EXHAUST, TRANSFER, MAKEUP OR OUTSIDE AIR GRILLE, OR REGISTER
-  THERMOSTAT PROGRAMMABLE HEAT/COOL BALANCING DAMPER
-  OUTLET OR INLET CFM