



**1 1ST FLOOR POWER PLAN**  
SCALE: 1/8" = 1 FT

**SYMBOL LEGEND**

| POWER                  |  |
|------------------------|--|
|                        | 20 AMP DUPLEX RECEPTACLE                     |
|                        | 20 AMP GFCI DUPLEX RECEPTACLE                |
|                        | 20 AMP SURGE SUPPRESSING DUPLEX RECEPTACLE * |
|                        | 20 AMP DUPLEX ISOLATED GROUND RECEPTACLE     |
|                        | 20 AMP SINGLE RECEPTACLE                     |
|                        | 2-WAY SWITCH                                 |
|                        | 3-WAY SWITCH                                 |
|                        | WEATHER PROOF                                |
|                        | ELECTRICAL PANEL                             |
|                        | DISCONNECT SWITCH - SEE SCHEDULE             |
|                        | JUNCTION BOX                                 |
| INFORMATION TECHNOLOGY |  |
|                        | TELEPHONE JACK                               |
|                        | CAT5e DATA & TELEPHONE JACK                  |

**DISCONNECT SCHEDULE**

|  |  |
|--|--|
|  | 30 AMP, 1-POLE FUSED DISCONNECT, HP RATED, NEMA 1  |
|  | 30 AMP, 2-POLE FUSED DISCONNECT, HP RATED, NEMA 3R |
|  | 60 AMP, 2-POLE FUSED DISCONNECT, HP RATED, NEMA 3R |

**SHEET NOTES**

1 EXACT LOCATIONS AND HEIGHTS OF WIRING DEVICES ARE TO BE COORDINATED IN THE FIELD WITH EQUIPMENT AND CABINETRY.

**KEYED NOTES**

- ① COORDINATE MOUNTING HEIGHT WITH EXACT LOCATION OF MICROWAVE.
- ② FINAL LOCATION OF FLOOR BOX TO BE DETERMINED IN FIELD.
- ⑤ PROVIDE EMERGENCY SHUT OFF SWITCH FOR WATER HEATER. COORDINATE WITH EXACT LOCATION OF WATER HEATER IN FIELD.

FILE NAME: 0808 E3P.rvt; FILE PATH: \\work\ppl\hosp\proj\0808\0808 E3.rvt; PRINT DATE & TIME: November 26, 2008 11:45 am